

TYPE-EXAMINATION CERTIFICATE

Issued by Liftinstituut B.V.

- Certificate nr. : NL 07-400-1002-048-09 Revision nr. 1.0
- Description of the product : Inspection Box Connection Board
- Trademark, type : Arkel Elektrik, Inspection Box Connection Board REVKON V2.1
- Name and address of the manufacturer : Arkel Elektrik - Elektronik Tic. Ltd. Sti.
Bostanci Yolu Caddesi Güneyli Sokak No:5
Yukari Dudullu, Istanbul, Turkey
- Name and address of the certificate holder : Arkel Elektrik - Elektronik Tic. Ltd. Sti.
Bostanci Yolu Caddesi Güneyli Sokak No:5
Yukari Dudullu, Istanbul, Turkey
- Certificate issued on the basis of the following requirements : Lifts Directive 95/16/EC
EN 81-1 article 14.1.1, 14.1.2.1.3 and annex H
- Test laboratory : Liftinstituut
- Date and number of the laboratory report : March 21, 2007
NL 07-400-1002-048-09
- Date of type-examination : February 2007 – March 2007, March 5, 2010
- Annexes with this certificate : Report belonging to the type-examination certificate
nr.: NL 07-400-1002-048-09 rev. 1.0
- Additional remarks : The printed circuit board IS NOT subjected to the laboratory tests according to annex F.6 of EN 81-1/2.
- Conclusion : The printed circuit board meets the requirements referred to in this certificate taking into account any additional remarks mentioned above.

Issued in Amsterdam
Date of issue : March 5, 2010



Ir. V.M.A. Barendregt
Senior Officer Certification and Technology
Liftinstituut B.V.