

# TYPE-EXAMINATION CERTIFICATE FOR LIFTCOMPONENTS

Issued by Liftinstituut B.V.

Certificate nr. : NL14-400-1002-048-12      Revision no.: 2

Description of the product : Complete Lift Control Panel for electric lifts

Trademark, type : Arkel, ARCODE Lift Control Panel

Name and address of the manufacturer : Arkel Elektrik - Elektronik Tic. Ltd. Sti.  
Bostanci Yolu Cad. Sehit Sok. No:36  
Yukari Dudullu, Istanbul, Turkey

Name and address of the certificate holder : Arkel Elektrik - Elektronik Tic. Ltd. Sti.  
Bostanci Yolu Cad. Sehit Sok. No:36  
Yukari Dudullu, Istanbul, Turkey

Certificate issued on the following requirements : Lifts Directive 95/16/EC, EMC Directive 2004/108/EC

Certificate based on the following standards : Parts of : EN 81-1:1998+A3:2009

Test laboratory : ESIM

Date and number of the laboratory report : 10-02-2013 / EMC-2012314C (type 4B26A / 4B17A / 4B14A)  
08-04-2014 / EMC-2013359C (type 4C35A / 4C50A)

Date of type-examination : March – September 2013, Rev.1; November 7, 2014  
Rev.2; August 2015

Additional document with this certificate : Report belonging to the type-examination certificate  
no.: NL14-400-1002-048-12 rev.2

Additional remarks : The control panel IS NOT subjected to the laboratory tests  
according to annex F.6 of EN 81-1:1998 + A3:2009

Conclusion : The lift component meets the requirements referred to in this  
certificate taking into account any additional remarks  
mentioned above.

Amsterdam  
Date of issue : 04-09-2015  
Valid until : 31-08-2017



ing. A.J. van Ommen  
Manager Business Unit  
Certification



Certification decision by